



HQ 15EN Horn loudspeaker for voice alarm systems

AMC 2017 - 005
Revision 2019-03-20

EN54-24:2008
1438-CPR-0550
ISSUE DATE: 17
TYPE B




①




Remove mounting bracket from horn loudspeaker.

②



Fix mounting bracket on the flat surface.

③



HQ 15EN Circuit Diagram

* with capacitor

Connect speaker to signal line via block terminal.
(Select desired power from table)

Other technical data: see on doc. AMC 2017 - 04
Declaration of performance No: AMC-1613